# Dana për kabllo,izoluara

580/1VDEBI



## Profiles

1000V IEC 60900 · Premium

## Standards


DIN EN IEC 60900 (VDE 0682-201):2019-04; EN IEC 60900:2018

## Product features

- Materiali: çeliku të veçantë mjet
- rënie të falsifikuara, ngurtësuar tërësisht dhe nevrik
- prerja tehe induksion thekur
- kreu i lëmuar
- përfundojë sipërfaqe: krom kromuar për ISO 1456:2009 standarde
- të rënda në detyrë të dyfishtë - komponent trajton
- nofullave te thyera te një kënd prej 45 °

## E rëndësishme!


- Prerja e kabllo pa tela çeliku





| | L | A | max | |
|---|---|---|---|---|
| 610440 | 170 | 18 | 10 | 339 |
| 610441 | 230 | 22 | 17 | 444 |

* Imazhet e produkteve janë simbolike. Të gjitha dimensionet janë në mm, pesha në gram.Të gjitha dimensionet e listuara mund të ndryshojnë në tolerancë.

## Usage (pictures)





## Frequently asked questions

**Are certified insulated tools made through a different procedure than non-certified insulated tools?**
The tools are made according to the same procedure.

**Are insulated (VDE) tools considered as personal protective equipment (PPE)?**
According to EU regulations, VDE tools are not considered as PPE.

**Is it possible to work with insulated pliers under electrical voltage?**
Yes, but only by professionals who follow safety requirements and use additional personal protective equipment.

**Are the VDE tools only being sampled in series production?**
The high voltage test (at 10kV) is performed fully on each tool. Other tests are performed in accordance with the EN60900 standard.