μονωμένο πριόνι

753VDP



Προφίλ

1000V IEC 60900

Πρότυπα

DIN EN IEC 60900 (VDE 0682-201):2019-04; EN IEC 60900:2018

Χαρακτηριστικά προϊόντος


- Ανταλλακτική λεπίδα
- κατασκευασμένο σύμφωνα με τα πρότυπα DIN EN IEC 60900

Προτερήματα:

- Διπλή επίστρωση- διπλή μόνωση έγχρωμη

Σημαντικό!

- Εάν η δεύτερη επίστρωση φαίνεται, αντικαταστήστε το μονωμένο εργαλείο σας με ένα καινούργιο



	L	
615502	150	320

* Οι εικόνες των προϊόντων είναι συμβολικές. Ολες οι διαστάσεις είναι σε mm,το βάρος είναι σε γραμμάρια. Όλες οι αναφερόμενες διαστάσεις μπορεί να διαφέρουν σε ανοχές.

Ανταλλακτικά

Ανταλλακτικές λεπίδες για τα 753P και 753VDP

Συχνές ερωτήσεις

Are certified insulated tools made through a different procedure than non-certified insulated tools?
The tools are made according to the same procedure.

Are insulated (VDE) tools considered as personal protective equipment (PPE)?
According to EU regulations, VDE tools are not considered as PPE.

Are the VDE tools only being sampled in series production?
The high voltage test (at 10kV) is performed fully on each tool. Other tests are performed in accordance with the EN60900 standard.