Clesti combinati cu gaura

Hidden

420/1VDEDP



Profile

1000V IEC 60900 Premium

Standarde

DIN EN IEC 60900 (VDE 0682-201):2019-04; EN IEC 60900:2018

Caracteristicile produsului


- material:compozitie speciala pentru calire revenire
- tratat complet
- partile taietoare tratate prin inductie
- cap polizat
- finisare:cromat in conformitate cu standardul ISO 1456:2009
- in conformitate cu standardul EN IEC 60900

Avantaje:

- manerele izolate cu doua straturi de culori diferite care permit o protectie suplimentara

Important

- daca al doilea strat devine vizibil inlocuiti scula VDE cu una noua






	L	B	C	A	
619176	180	24	45	11	221

capacitatea de taiere (10N=1kg)

	L	max 1560 N/mm² Ø	max 750 N/mm² Ø
619176	180	1,8	2,5

* Imaginea produsului este simbolica.Toate dimensiunile sunt exprimate în mm,greutatea în grame.

0 (pictures)


Safety tips

- Pliers should be oiled regularly. A drop of oil at the hinge will lengthen the tool life and assure easy operation.
- When cutting wire with pliers, you should always wear glasses or goggles.

- Don't use pliers for cutting hardened wire, unless specifically manufactured for this purpose.
- Don't expose pliers to excessive heat. This may ruin the tool.
- Don't use pliers as a hammer.
- Don't hammer on the handles. They may crack or break.
- Don't extend the length of plier handles to secure greater leverage.
- Don't use pliers on nuts or bolts. A wrench will do a better job and with less risk of damage to the fastener.

Frequently asked questions

Uneltele izolate certificate sunt realizate printr-o procedură diferită de cea a instrumentelor izolate necertificate?
Instrumentele sunt realizate în conformitate cu aceeași procedură.

Instrumentele izolate (VDE) sunt considerate echipamente individuale de protecție (EIP)?
În conformitate cu reglementările UE, instrumentele VDE nu sunt considerate EIP.

Este posibil să lucrați cu clești izolați sub tensiune electrică?
Da, dar numai de către profesioniștii care respectă cerințele de siguranță și folosesc echipamente individuale de protecție suplimentare.

Instrumentele VDE sunt testate în producția de serie doar pe esantioane?
Testul de înaltă tensiune (la 10kV) se efectuează complet pe fiecare instrument. Alte teste sunt efectuate în conformitate cu standardul EN60900.