Μονωμένο πριόνι

750VDP



Προφίλ


1000V IEC 60900

Πρότυπα

DIN EN IEC 60900 (VDE 0682-201):2019-04; EN IEC 60900:2018

Χαρακτηριστικά προϊόντος

- κατασκευασμένο σύμφωνα με τα πρότυπα DIN EN IEC 60900



	L	L1	B	
619098	460	300	149	815

* Οι εικόνες των προϊόντων είναι συμβολικές. Ολες οι διαστάσεις είναι σε mm,το βάρος είναι σε γραμμάρια. Όλες οι αναφερόμενες διαστάσεις μπορεί να διαφέρουν σε ανοχές.

Ανταλλακτικά

 Ανταλλακτική λάμα για 750B

Σχετικά προϊόντα

 μονωμένο πριόνι

 Σιδηροπρίονο με πλαστική λαβή

 Σιδηροπρίονο με διπλή λαβή

Συχνές ερωτήσεις

Are certified insulated tools made through a different procedure than non-certified insulated tools?
The tools are made according to the same procedure.

Are insulated (VDE) tools considered as personal protective equipment (PPE)?
According to EU regulations, VDE tools are not considered as PPE.

Are the VDE tools only being sampled in series production?
The high voltage test (at 10kV) is performed fully on each tool. Other tests are performed in accordance with the EN60900 standard.